

JANUARY 2009

PLANT/PHYSICAL HEALTH AND SAFETY

There were no plant/physical health and safety issues to report. Inspections were conducted.

The agency annual fire inspections were conducted in Lancaster and Columbus. Two of the buildings in Lancaster required re-inspection due to emergency exit light issues. These issues were resolved and the buildings passed re-inspection.

Security cameras were installed in the Columbus office reception and waiting area.